

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	15.1 cd per klm.
(Luminaire orientation as tested.)	7.0 degrees vertical
	16.0 degrees horizontal

Beam Spread	At 10% of Imax	163.4V x 165.1H
	At 50% of Imax	145.4V x 146.0H
	At 90% of Imax	127.9V x 136.0H

Beam Flux	Total	15.1 lumens per klm.
	To 10% of Imax	13.3 lumens per klm.
	To 50% of Imax	3.9 lumens per klm.
	To 90% of Imax	0.1 lumens per klm.

Upward LOR	0.0 %
Downward LOR	1.5 %


Luminaire Efficiency (Light Output Ratio)	1.5 %
---	-------

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 06 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: 96GRFLED070/T3	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:



DATA OF LAMP		PHOTOMETRIC DATA	
MODEL	996GRFLED070/T3	Imax (cd)	55.33
NOMINAL POWER (W)	7	AVAILABILITY (%)	1.3
RATED VOLTAGE (V)	230	Avai. FLUX (lm)	48.93
NOMINAL FLUX (lm)	525	LOR (%)	1.5
LAMPS INSIDE	7	TOTAL FLUX (lm)	55.66
TEST VOLTAGE (V)	230	θ @50% (H,V)	146,145DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		Φ t	Φ a
	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.10	0.00
90	0.00	0.00	0.00	0.01	0.02	0.02	0.03	0.04	0.06	0.06	0.06	0.06	0.05	0.03	0.01	0.00	0.00	0.00	0.47	0.00
80	0.00	0.00	0.01	0.02	0.04	0.06	0.08	0.11	0.15	0.16	0.16	0.14	0.11	0.07	0.03	0.01	0.00	0.00	1.18	0.30
70	0.00	0.01	0.02	0.05	0.08	0.11	0.16	0.23	0.23	0.22	0.24	0.23	0.16	0.10	0.06	0.02	0.00	0.00	1.91	1.37
60	0.00	0.01	0.04	0.07	0.11	0.14	0.23	0.33	0.34	0.34	0.34	0.30	0.22	0.15	0.08	0.03	0.01	0.00	2.74	2.38
50	0.00	0.01	0.05	0.09	0.13	0.21	0.34	0.44	0.51	0.55	0.58	0.41	0.25	0.18	0.11	0.04	0.01	0.00	3.90	3.69
40	0.00	0.02	0.05	0.10	0.16	0.29	0.51	0.61	0.52	0.75	0.70	0.51	0.33	0.21	0.12	0.05	0.01	0.00	4.94	4.77
30	0.00	0.02	0.06	0.13	0.21	0.37	0.58	0.99	0.74	1.14	1.22	0.74	0.46	0.25	0.12	0.05	0.01	0.00	7.09	6.94
20	0.00	0.02	0.07	0.14	0.24	0.42	0.74	1.11	0.41	0.60	1.30	0.92	0.46	0.26	0.13	0.05	0.01	0.00	6.89	6.73
10	0.00	0.02	0.07	0.13	0.22	0.40	0.72	0.94	0.46	0.74	0.97	0.55	0.43	0.25	0.14	0.05	0.01	0.00	6.12	5.98
0	0.00	0.02	0.06	0.11	0.18	0.35	0.52	0.65	1.04	1.29	0.98	0.57	0.42	0.22	0.13	0.05	0.01	0.00	6.60	6.45
-10	0.00	0.02	0.05	0.09	0.15	0.29	0.43	0.57	0.91	0.70	0.59	0.46	0.27	0.18	0.12	0.04	0.01	0.00	4.88	4.68
-20	0.00	0.01	0.04	0.08	0.14	0.25	0.36	0.45	0.49	0.50	0.53	0.31	0.18	0.13	0.09	0.04	0.01	0.00	3.60	3.30
-30	0.00	0.01	0.03	0.07	0.11	0.19	0.23	0.27	0.26	0.27	0.29	0.22	0.14	0.10	0.06	0.03	0.01	0.00	2.28	1.85
-40	0.00	0.01	0.02	0.05	0.07	0.11	0.14	0.15	0.15	0.17	0.19	0.17	0.12	0.08	0.05	0.02	0.00	0.00	1.51	0.50
-50	0.00	0.00	0.01	0.02	0.04	0.05	0.08	0.10	0.10	0.11	0.12	0.12	0.10	0.06	0.03	0.01	0.00	0.00	0.97	0.00
-60	0.00	0.00	0.00	0.01	0.01	0.02	0.03	0.04	0.05	0.05	0.06	0.05	0.04	0.02	0.01	0.00	0.00	0.00	0.40	0.00
-70	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.09	0.00
-80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HORIZONTAL (DEG)																				
Φ t	0.02	0.18	0.61	1.17	1.92	3.31	5.19	7.05	6.45	7.69	8.36	5.78	3.74	2.29	1.29	0.50	0.10	0.01	56	---
Φ a	0.00	0.00	0.09	0.60	1.46	2.89	4.78	6.62	5.93	7.28	8.00	5.37	3.23	1.81	0.86	0.00	0.00	0.00	---	49

one-half-peak spread: U:9.3,D:11.4 , L:25.3,R:33.4


NEMA Beam Type: Type 7

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature:25.3°C
Operators:
Test Date:06 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME: 96GRFLED070/T3	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:




C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: HIGH
 Temperature:25.3°C
 Operators:
 Test Date:06 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity:65.0%
 Test Distance:6.265m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM


NAME: 96GRFLED070/T3	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:



C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: HIGH
 Temperature: 25.3°C
 Operators:
 Test Date: 06 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

Planar Illuminance Curve




C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 06 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

AAI Figure

NAME: 96GRFLED070/T3	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: HIGH
 Temperature:25.3°C
 Operators:
 Test Date:06 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity:65.0%
 Test Distance:6.265m [K=1.0000]
 Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRFLED070/T3	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:

Table--1

UNIT: cd

H(DEC) V(DEC)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.24	0.25	0.25	0.23	0.21	0.12	0.04	0.05	0.06	0.11	0.16	0.15	0.15	0.14	0.13	0.09	0.06	0.04	0.03
-85	0.24	0.25	0.26	0.25	0.24	0.17	0.12	0.14	0.16	0.19	0.21	0.23	0.25	0.23	0.21	0.22	0.23	0.21	0.19
-80	0.24	0.26	0.27	0.26	0.28	0.24	0.21	0.24	0.27	0.30	0.34	0.38	0.39	0.38	0.37	0.48	0.61	0.61	0.60
-75	0.24	0.26	0.27	0.30	0.34	0.33	0.31	0.40	0.46	0.59	0.69	0.73	0.82	0.96	1.08	1.33	1.60	1.61	1.58
-70	0.24	0.27	0.30	0.34	0.41	0.48	0.58	0.80	0.95	1.08	1.32	1.49	1.59	1.79	2.03	2.32	2.53	2.57	2.60
-65	0.24	0.27	0.32	0.41	0.54	0.73	1.07	1.38	1.59	1.91	2.01	2.09	2.52	2.91	3.29	3.49	3.56	3.49	3.33
-60	0.24	0.27	0.35	0.47	0.72	1.11	1.60	2.19	2.55	2.67	2.66	2.86	3.55	4.21	4.67	4.50	4.08	4.06	4.18
-55	0.24	0.29	0.39	0.59	1.00	1.55	2.28	3.05	3.16	3.33	3.66	4.18	4.95	5.12	5.18	5.13	4.92	5.03	5.39
-50	0.24	0.30	0.44	0.71	1.31	2.04	2.87	3.45	3.65	4.16	4.96	6.12	6.71	6.17	6.24	6.43	5.65	5.38	5.68
-45	0.24	0.31	0.48	0.89	1.67	2.60	3.30	3.74	4.20	4.70	6.83	8.10	7.81	8.06	8.59	9.17	9.11	8.61	7.52
-40	0.24	0.32	0.53	1.11	2.02	3.00	3.68	4.06	4.28	5.64	8.08	9.45	9.64	10.5	11.2	12.7	12.7	11.7	12.6
-35	0.24	0.33	0.61	1.33	2.44	3.35	3.97	4.34	4.91	6.22	8.37	9.97	11.4	13.3	14.4	15.1	16.3	16.4	15.9
-30	0.24	0.34	0.68	1.55	2.84	3.64	4.35	4.62	5.49	6.62	8.57	10.4	13.6	16.2	15.8	17.3	23.1	21.1	15.0
-25	0.24	0.35	0.74	1.75	3.16	3.88	4.78	5.13	5.77	7.02	8.96	11.0	15.0	16.4	14.0	18.0	29.7	32.7	25.1
-20	0.24	0.35	0.80	1.93	3.45	4.27	5.11	5.64	6.17	7.35	9.64	12.1	17.7	15.4	15.8	18.3	29.9	39.2	38.9
-15	0.24	0.36	0.85	2.09	3.73	4.71	5.41	6.06	6.51	7.86	10.6	13.3	17.5	18.2	20.0	21.5	24.6	36.9	38.8
-10	0.24	0.36	0.89	2.21	4.00	5.09	5.90	6.94	7.15	8.48	11.7	15.5	17.5	22.9	27.8	24.9	24.8	25.1	35.6
-5	0.24	0.37	0.92	2.31	4.24	5.41	6.46	7.89	8.40	9.81	13.7	17.3	17.1	27.1	36.8	33.1	23.4	10.1	7.72
0	0.24	0.37	0.94	2.37	4.44	5.68	7.04	8.80	9.66	10.9	15.9	18.5	18.7	27.9	41.4	40.3	27.4	6.45	4.50
5	0.24	0.37	0.94	2.34	4.27	5.36	6.64	8.48	8.93	10.9	15.6	17.9	16.8	25.1	39.4	39.2	31.3	8.49	5.41
10	0.24	0.37	0.92	2.27	4.07	5.02	6.19	8.03	8.25	10.5	14.6	17.6	14.1	21.6	36.5	37.3	28.4	21.6	22.5
15	0.24	0.36	0.90	2.16	3.85	4.66	5.67	7.44	7.89	9.28	12.7	17.2	13.4	18.8	30.9	37.6	27.6	23.9	25.5
20	0.24	0.36	0.86	2.03	3.64	4.32	5.26	6.70	7.46	8.34	10.7	14.2	15.4	18.8	28.6	30.5	24.0	22.9	30.0
25	0.24	0.35	0.81	1.86	3.44	4.10	5.01	5.93	6.77	7.36	8.72	11.7	13.9	20.3	22.7	20.6	15.5	15.2	19.3
30	0.24	0.35	0.74	1.67	3.19	3.89	4.62	5.24	6.23	6.54	7.14	10.1	12.6	15.2	17.1	14.3	12.1	13.2	17.6
35	0.24	0.34	0.66	1.47	2.76	3.61	4.29	5.13	5.56	6.20	6.29	8.19	10.7	11.8	13.7	16.1	17.5	19.3	21.3
40	0.24	0.33	0.57	1.29	2.28	3.38	4.05	4.52	4.82	5.62	5.88	6.39	8.21	9.88	11.2	13.9	14.8	14.3	12.5
45	0.24	0.32	0.51	1.09	1.89	3.13	3.49	3.85	4.45	4.96	5.57	5.65	6.39	8.45	9.62	11.6	11.6	10.9	10.3
50	0.24	0.31	0.47	0.88	1.50	2.44	3.05	3.26	3.69	4.19	4.77	4.69	5.33	6.50	8.28	9.45	10.4	10.1	8.43
55	0.24	0.30	0.43	0.69	1.16	1.79	2.45	2.75	3.04	3.47	4.05	4.55	4.74	5.67	7.06	8.43	8.52	7.82	6.66
60	0.24	0.28	0.38	0.50	0.82	1.25	1.63	2.10	2.50	2.77	3.07	3.58	3.88	4.24	4.69	5.45	5.89	5.61	5.06
65	0.24	0.28	0.35	0.43	0.58	0.81	1.04	1.33	1.73	2.03	2.26	2.50	2.67	2.86	3.06	3.69	4.63	5.09	5.37
70	0.24	0.27	0.33	0.35	0.41	0.53	0.64	0.82	1.02	1.24	1.38	1.58	1.76	2.00	2.20	2.66	3.24	3.68	4.09
75	0.24	0.26	0.30	0.31	0.31	0.36	0.39	0.49	0.59	0.66	0.74	0.87	0.99	1.09	1.25	1.39	1.48	1.73	1.98
80	0.24	0.25	0.27	0.26	0.25	0.25	0.27	0.29	0.32	0.34	0.35	0.40	0.45	0.51	0.56	0.57	0.57	0.64	0.72
85	0.24	0.24	0.25	0.22	0.19	0.17	0.16	0.17	0.18	0.21	0.23	0.23	0.23	0.26	0.28	0.25	0.22	0.24	0.27
90	0.24	0.23	0.22	0.18	0.14	0.09	0.03	0.04	0.05	0.09	0.14	0.14	0.14	0.14	0.14	0.11	0.07	0.07	0.07

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:06 October 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRFLED070/T3	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:

Table--2

UNIT: cd

H (DEG) V (DEG)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.07	0.11	0.14	0.17	0.18	0.18	0.17	0.17	0.15	0.14	0.08	0.03	0.05	0.07	0.10	0.14	0.15	0.15	
-85	0.24	0.29	0.30	0.32	0.33	0.35	0.32	0.30	0.28	0.27	0.20	0.13	0.13	0.13	0.14	0.16	0.15	0.15	
-80	0.69	0.77	0.79	0.79	0.72	0.66	0.58	0.49	0.44	0.40	0.31	0.23	0.20	0.18	0.17	0.17	0.16	0.15	
-75	1.78	1.93	1.85	1.79	1.82	1.77	1.50	1.21	0.89	0.67	0.50	0.34	0.29	0.24	0.21	0.18	0.17	0.15	
-70	2.84	3.07	3.24	3.33	3.38	3.22	2.82	2.29	1.71	1.23	0.89	0.57	0.42	0.32	0.25	0.21	0.18	0.15	
-65	3.62	3.87	3.96	4.13	4.36	4.40	4.10	3.46	2.67	1.99	1.44	0.97	0.59	0.41	0.31	0.23	0.19	0.15	
-60	4.52	4.77	4.81	4.88	5.31	5.14	4.76	4.22	3.39	2.83	2.19	1.41	0.88	0.52	0.36	0.26	0.20	0.15	
-55	6.06	6.59	6.84	6.50	5.80	4.83	5.19	4.55	3.79	3.36	2.87	2.04	1.20	0.70	0.44	0.29	0.21	0.15	
-50	6.59	7.45	8.47	8.42	7.65	6.24	5.18	4.31	4.34	3.70	3.24	2.55	1.60	0.88	0.51	0.32	0.22	0.15	
-45	8.39	9.08	9.30	9.10	8.28	6.12	5.73	5.08	4.07	4.19	3.74	2.94	2.10	1.09	0.60	0.35	0.23	0.15	
-40	13.5	14.0	13.4	11.3	8.28	6.41	5.88	5.51	4.84	4.34	4.46	3.41	2.39	1.30	0.69	0.38	0.24	0.15	
-35	19.5	20.5	19.6	16.0	11.1	8.18	6.75	6.27	5.77	5.55	5.16	4.01	2.64	1.65	0.77	0.42	0.25	0.15	
-30	13.5	16.6	20.1	17.6	13.3	10.6	8.50	7.43	6.88	7.10	5.75	4.35	2.90	1.98	0.86	0.45	0.25	0.15	
-25	21.6	19.8	18.9	18.9	17.0	12.9	9.93	8.82	8.64	8.15	6.63	4.61	3.08	2.11	0.94	0.48	0.26	0.15	
-20	38.3	31.4	25.6	20.8	20.5	18.6	13.4	10.8	9.34	8.61	7.32	4.89	3.26	2.22	1.00	0.50	0.27	0.15	
-15	42.9	43.7	33.1	25.3	19.4	20.5	17.0	13.0	9.76	9.14	7.82	5.26	3.52	2.36	1.04	0.51	0.27	0.15	
-10	45.6	44.5	40.4	26.1	19.3	17.6	19.5	14.6	10.6	9.16	7.95	5.50	3.77	2.49	1.06	0.52	0.27	0.15	
-5	22.5	31.6	30.7	26.8	16.8	15.6	19.0	15.2	11.1	9.42	7.80	5.56	3.98	2.61	1.07	0.53	0.28	0.15	
0	7.42	33.1	35.5	31.8	23.2	16.9	15.0	15.2	11.1	9.83	7.46	5.51	4.15	2.68	1.06	0.53	0.28	0.15	
5	13.1	34.0	49.8	44.0	34.8	24.1	18.2	15.3	11.5	9.37	7.29	5.51	4.19	2.58	1.07	0.52	0.28	0.15	
10	38.1	46.1	52.4	44.4	39.7	27.1	19.1	15.1	11.5	8.72	7.01	5.47	4.16	2.41	1.06	0.52	0.27	0.15	
15	39.6	44.2	45.3	33.1	24.4	23.6	17.7	15.5	11.2	8.30	6.71	5.41	4.06	2.21	1.04	0.50	0.27	0.15	
20	35.1	37.9	29.4	21.2	18.3	17.0	15.8	13.8	10.7	8.15	6.96	5.46	3.88	1.99	1.00	0.48	0.27	0.15	
25	24.3	25.6	23.0	19.2	18.9	16.3	12.5	10.8	9.60	8.65	6.94	5.50	3.64	1.77	0.93	0.46	0.26	0.15	
30	20.4	19.9	22.2	23.8	18.0	13.7	10.6	9.34	8.62	8.50	6.60	5.28	3.24	1.60	0.85	0.43	0.26	0.15	
35	19.9	18.8	20.5	18.4	14.7	11.4	9.56	9.04	8.84	7.61	6.49	4.80	2.84	1.54	0.75	0.40	0.25	0.15	
40	13.6	15.7	15.7	14.0	11.7	10.1	9.41	8.79	8.10	6.41	5.70	3.98	2.60	1.41	0.66	0.36	0.24	0.15	
45	11.6	11.7	11.1	11.1	10.8	9.70	9.09	8.10	6.55	6.11	4.55	3.44	2.35	1.24	0.58	0.33	0.23	0.15	
50	8.78	9.10	9.50	9.99	10.0	9.04	7.91	6.69	6.08	4.61	3.70	2.96	2.00	1.02	0.50	0.31	0.22	0.15	
55	7.08	7.66	8.47	8.60	8.12	7.19	5.92	5.37	4.52	3.83	3.22	2.42	1.55	0.83	0.43	0.29	0.21	0.15	
60	5.75	6.43	7.13	7.43	6.92	5.79	4.97	4.46	3.84	3.31	2.58	1.78	1.12	0.62	0.35	0.27	0.20	0.15	
65	5.44	5.50	5.63	5.36	5.01	4.81	4.25	3.77	3.30	2.50	1.80	1.22	0.76	0.47	0.31	0.24	0.19	0.15	
70	3.81	3.56	3.79	3.90	3.84	3.64	3.22	2.69	2.11	1.58	1.11	0.72	0.51	0.34	0.26	0.22	0.18	0.15	
75	2.02	2.03	2.13	2.18	2.16	2.05	1.78	1.50	1.12	0.80	0.60	0.44	0.34	0.26	0.22	0.20	0.17	0.15	
80	0.76	0.79	0.86	0.90	0.90	0.89	0.78	0.64	0.52	0.41	0.34	0.26	0.23	0.20	0.18	0.18	0.16	0.15	
85	0.29	0.32	0.36	0.39	0.37	0.36	0.35	0.34	0.29	0.24	0.21	0.17	0.16	0.14	0.15	0.16	0.15	0.15	
90	0.11	0.14	0.18	0.21	0.21	0.20	0.20	0.20	0.17	0.15	0.11	0.07	0.08	0.08	0.11	0.14	0.14	0.15	

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:06 October 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks: