


LUMINAIRE PHOTOMETRIC TEST REPORT


| | | |
|-----------------------------|-------------|------------------|
| NAME: 99XLED637W | TYPE: | WEIGHT: 1 |
| SPEC.: | DIM.: F 170 | SERIAL No.: 0 |
| MFR.: Elmark Industries JSC | SUR.: round | Shielding Angle: |

| DATA OF LAMP | | PHOTOMETRIC DATA | | | |
|-------------------|------------|------------------|--------|--------------------------|-----------|
| MODEL | 99XLED637W | Imax (cd) | 261.9 | S/MH (C0/180) | 1.26 |
| NOMINAL POWER (W) | 12 | LOR (%) | 78.6 | S/MH (C90/270) | 1.27 |
| RATED VOLTAGE (V) | 230 | TOTAL FLUX (lm) | 762.06 | η UP, DN (C0-180) | 0.0, 38.9 |
| NOMINAL FLUX (lm) | 970 | CIE CLASS | DIRECT | η UP, DN (C180-360) | 0.0, 39.6 |
| LAMPS INSIDE | 1 | η up (%) | 0.0 | CIBSE SHR NOM | 1.25 |
| TEST VOLTAGE (V) | 230 | η down (%) | 78.6 | CIBSE SHR MAX | 1.35 |

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature: 25.3°C
Operators:
Test Date: 24 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

| γ | C0 | C45 | C90 | C135 | C180 | C225 | C270 | C315 | γ | Φ zone | Φ total | %lum, lamp |
|----------|-----------------------|--------|--------|--------|--------|--------|--------|--------|----------|-------------|--------------|------------|
| 10 | 257.7 | 257.3 | 257.1 | 257.0 | 257.4 | 257.7 | 257.9 | 257.9 | 0- 10 | 24.79 | 24.79 | 3.25,2.56 |
| 20 | 244.7 | 244.1 | 243.6 | 243.5 | 244.2 | 245.0 | 245.3 | 245.1 | 10- 20 | 71.14 | 95.93 | 12.6,9.89 |
| 30 | 223.5 | 222.7 | 221.8 | 221.8 | 222.8 | 224.0 | 224.4 | 224.0 | 20- 30 | 108.2 | 204.1 | 26.8,21 |
| 40 | 194.6 | 193.7 | 192.6 | 192.5 | 193.8 | 195.4 | 195.8 | 195.4 | 30- 40 | 131.1 | 335.2 | 44,34.6 |
| 50 | 159.1 | 158.3 | 157.1 | 156.8 | 158.6 | 160.3 | 160.6 | 160.2 | 40- 50 | 136.7 | 471.9 | 61.9,48.6 |
| 60 | 118.2 | 117.4 | 115.8 | 115.4 | 117.6 | 119.7 | 119.8 | 119.3 | 50- 60 | 124.1 | 596.0 | 78.2,61.4 |
| 70 | 74.70 | 74.00 | 72.01 | 71.17 | 73.81 | 76.41 | 76.37 | 75.17 | 60- 70 | 95.15 | 691.2 | 90.7,71.3 |
| 80 | 32.15 | 31.64 | 29.88 | 29.14 | 31.49 | 33.72 | 33.47 | 32.05 | 70- 80 | 55.44 | 746.6 | 98,77 |
| 90 | 0.4082 | 0.4191 | 0.4166 | 0.4125 | 0.3592 | 0.3593 | 0.3703 | 0.3553 | 80- 90 | 15.45 | 762.1 | 100,78.6 |
| 100 | | | | | | | | | 90-100 | | | |
| 110 | | | | | | | | | 100-110 | | | |
| 120 | | | | | | | | | 110-120 | | | |
| 130 | | | | | | | | | 120-130 | | | |
| 140 | | | | | | | | | 130-140 | | | |
| 150 | | | | | | | | | 140-150 | | | |
| 160 | | | | | | | | | 150-160 | | | |
| 170 | | | | | | | | | 160-170 | | | |
| 180 | | | | | | | | | 170-180 | | | |
| DEG | LUMINOUS INTENSITY:cd | | | | | | | | | UNIT:lm | | |

Conical surface Flux(90deg): 404 lm

%lum = 53.0%

%lamp = 41.6%

Conical surface Flux(130deg): 648.04 lm

%lum = 85.0%


%lamp = 66.8%

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:24 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES

| | | |
|-----------------------------|-------------|------------------|
| NAME: 99XLED637W | TYPE: | WEIGHT: 1 |
| SPEC.: | DIM.: F 170 | SERIAL No.: 0 |
| MFR.: Elmark Industries JSC | SUR.: round | Shielding Angle: |



| LUMINANCE cd/(m2) | | |
|-------------------|--------|---------|
| G (DEG) | C0/180 | C90/270 |
| 85 | 9590 | 8380 |
| 80 | 11305 | 10501 |
| 75 | 12464 | 11845 |
| 70 | 13336 | 12848 |
| 65 | 13933 | 13575 |
| 60 | 14433 | 14137 |
| 55 | 14821 | 14575 |
| 50 | 15112 | 14911 |
| 45 | 15339 | 15140 |


C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature: 25.3°C
Operators:
Test Date: 24 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

| | | |
|-----------------------------|-------------|------------------|
| NAME: 99XLED637W | TYPE: | WEIGHT: 1 |
| SPEC.: | DIM.: F 170 | SERIAL No.: 0 |
| MFR.: Elmark Industries JSC | SUR.: round | Shielding Angle: |

| pcc | 80% | | | 70% | | | 50% | | | 30% | | | 10% | | | 0 |
|-----|-----------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---|
| pw | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 0 |
| pfc | 20% | | | 20% | | | 20% | | | 20% | | | 20% | | | 0 |
| RCR | RCR:Room Cavity Ratio | | | | | | | | | | | | | | | |



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:24 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

WEC AND CCEC

| | | |
|-----------------------------|-------------|------------------|
| NAME: 99XLED637W | TYPE: | WEIGHT: 1 |
| SPEC.: | DIM.: F 170 | SERIAL No.: 0 |
| MFR.: Elmark Industries JSC | SUR.: round | Shielding Angle: |

| pcc | 80% | | | 70% | | | 50% | | | 30% | | | 10% | | | 0 |
|------|-----------------------|------|------|------|------|------|---------------------------------|------|------|------|------|------|------|------|------|---|
| pw | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 0 |
| pfc | 20% | | | 20% | | | 20% | | | 20% | | | 20% | | | 0 |
| RCR | RCR:Room Cavity Ratio | | | | | | Wall Exitance Coefficients(WEC) | | | | | | | | | |
| 0.0 | | | | | | | | | | | | | | | | |
| 1.0 | .246 | .140 | .044 | .241 | .137 | .044 | .230 | .132 | .042 | .221 | .127 | .041 | .212 | .123 | .040 | |
| 2.0 | .231 | .127 | .039 | .226 | .125 | .038 | .217 | .121 | .038 | .209 | .117 | .037 | .201 | .114 | .036 | |
| 3.0 | .214 | .114 | .034 | .209 | .112 | .034 | .201 | .109 | .033 | .194 | .106 | .033 | .187 | .103 | .032 | |
| 4.0 | .197 | .102 | .030 | .193 | .101 | .030 | .186 | .099 | .029 | .179 | .096 | .029 | .173 | .094 | .029 | |
| 5.0 | .182 | .093 | .027 | .179 | .092 | .027 | .172 | .090 | .026 | .166 | .088 | .026 | .161 | .086 | .026 | |
| 6.0 | .169 | .085 | .024 | .166 | .084 | .024 | .160 | .082 | .024 | .155 | .080 | .024 | .150 | .079 | .023 | |
| 7.0 | .157 | .078 | .022 | .154 | .077 | .022 | .149 | .075 | .022 | .144 | .074 | .022 | .140 | .073 | .021 | |
| 8.0 | .147 | .072 | .020 | .144 | .071 | .020 | .140 | .070 | .020 | .135 | .069 | .020 | .131 | .067 | .020 | |
| 9.0 | .137 | .066 | .019 | .135 | .066 | .018 | .131 | .065 | .018 | .127 | .064 | .018 | .123 | .063 | .018 | |
| 10.0 | .129 | .062 | .017 | .127 | .061 | .017 | .123 | .060 | .017 | .120 | .060 | .017 | .117 | .059 | .017 | |

| pcc | 80% | | | 70% | | | 50% | | | 30% | | | 10% | | | 0 |
|------|-----------------------|------|------|------|------|------|---|------|------|------|------|------|------|------|------|---|
| pw | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 0 |
| pfc | 20% | | | 20% | | | 20% | | | 20% | | | 20% | | | 0 |
| RCR | RCR:Room Cavity Ratio | | | | | | Ceiling Cavity Exitance Coefficients (CCEC) | | | | | | | | | |
| 0.0 | .150 | .150 | .150 | .128 | .128 | .128 | .087 | .087 | .087 | .050 | .050 | .050 | .016 | .016 | .016 | |
| 1.0 | .142 | .123 | .105 | .121 | .105 | .091 | .083 | .072 | .063 | .048 | .042 | .036 | .015 | .013 | .012 | |
| 2.0 | .136 | .104 | .077 | .116 | .089 | .066 | .080 | .062 | .046 | .046 | .036 | .027 | .015 | .012 | .009 | |
| 3.0 | .130 | .090 | .058 | .111 | .077 | .050 | .076 | .054 | .035 | .044 | .031 | .021 | .014 | .010 | .007 | |
| 4.0 | .124 | .079 | .046 | .106 | .069 | .040 | .073 | .048 | .028 | .042 | .028 | .017 | .014 | .009 | .005 | |
| 5.0 | .118 | .071 | .037 | .101 | .062 | .032 | .070 | .043 | .023 | .040 | .025 | .013 | .013 | .008 | .004 | |
| 6.0 | .112 | .065 | .031 | .096 | .056 | .027 | .066 | .039 | .019 | .039 | .023 | .011 | .012 | .008 | .004 | |
| 7.0 | .107 | .059 | .026 | .092 | .051 | .023 | .063 | .036 | .016 | .037 | .021 | .010 | .012 | .007 | .003 | |
| 8.0 | .102 | .055 | .022 | .087 | .047 | .020 | .060 | .033 | .014 | .035 | .020 | .008 | .011 | .006 | .003 | |
| 9.0 | .097 | .051 | .020 | .083 | .044 | .017 | .058 | .031 | .012 | .034 | .018 | .007 | .011 | .006 | .002 | |
| 10.0 | .092 | .047 | .018 | .080 | .041 | .015 | .055 | .029 | .011 | .032 | .017 | .006 | .010 | .006 | .002 | |

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:24 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

| | | | | | | | | | | | |
|---|--------|------------------|------|------|-------------|------|----------------|------------------|------|------|------|
| NAME: 99XLED637W | | | | | TYPE: | | | WEIGHT: 1 | | | |
| SPEC.: | | | | | DIM.: F 170 | | | SERIAL No.: 0 | | | |
| MFR.: Elmark Industries JSC | | | | | SUR.: round | | | Shielding Angle: | | | |
| ceiling/cavity | 0.7 | 0.7 | 0.5 | 0.5 | 0.3 | 0.7 | 0.7 | 0.5 | 0.5 | 0.3 | |
| walls | 0.5 | 0.3 | 0.5 | 0.3 | 0.3 | 0.5 | 0.3 | 0.5 | 0.3 | 0.3 | |
| working plane | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | |
| Room dimensions | | Viewed crosswise | | | | | Viewed endwise | | | | |
| x = 2H | y = 2H | 22.4 | 23.9 | 22.6 | 24.1 | 24.3 | 22.3 | 23.8 | 22.5 | 24.0 | 24.2 |
| | 3H | 23.9 | 25.3 | 24.2 | 25.6 | 25.8 | 23.8 | 25.2 | 24.1 | 25.4 | 25.7 |
| | 4H | 24.5 | 25.9 | 24.9 | 26.1 | 26.4 | 24.4 | 25.7 | 24.7 | 26.0 | 26.2 |
| | 6H | 25.0 | 26.3 | 25.3 | 26.5 | 26.8 | 24.8 | 26.1 | 25.1 | 26.3 | 26.6 |
| | 8H | 25.1 | 26.4 | 25.5 | 26.7 | 26.9 | 24.9 | 26.1 | 25.3 | 26.4 | 26.7 |
| | 12H | 25.2 | 26.4 | 25.6 | 26.7 | 27.0 | 25.0 | 26.2 | 25.3 | 26.5 | 26.8 |
| 4H | 2H | 23.0 | 24.3 | 23.3 | 24.6 | 24.8 | 22.9 | 24.3 | 23.2 | 24.5 | 24.8 |
| | 3H | 24.7 | 25.9 | 25.1 | 26.2 | 26.5 | 24.6 | 25.8 | 25.0 | 26.1 | 26.4 |
| | 4H | 25.5 | 26.6 | 25.8 | 26.9 | 27.2 | 25.3 | 26.4 | 25.7 | 26.7 | 27.1 |
| | 6H | 26.1 | 27.0 | 26.5 | 27.4 | 27.7 | 25.9 | 26.8 | 26.3 | 27.2 | 27.5 |
| | 8H | 26.3 | 27.1 | 26.7 | 27.5 | 27.9 | 26.0 | 26.9 | 26.5 | 27.3 | 27.7 |
| | 12H | 26.4 | 27.2 | 26.8 | 27.6 | 28.0 | 26.1 | 27.0 | 26.6 | 27.3 | 27.8 |
| 8H | 4H | 25.7 | 26.6 | 26.2 | 27.0 | 27.4 | 25.6 | 26.5 | 26.0 | 26.9 | 27.3 |
| | 6H | 26.5 | 27.2 | 26.9 | 27.6 | 28.0 | 26.3 | 27.0 | 26.7 | 27.5 | 27.9 |
| | 8H | 26.8 | 27.4 | 27.2 | 27.8 | 28.3 | 26.6 | 27.2 | 27.0 | 27.6 | 28.1 |
| | 12H | 27.0 | 27.5 | 27.4 | 28.0 | 28.4 | 26.7 | 27.3 | 27.2 | 27.7 | 28.2 |
| 12H | 4H | 25.8 | 26.6 | 26.2 | 27.0 | 27.4 | 25.6 | 26.5 | 26.1 | 26.8 | 27.2 |
| | 6H | 26.5 | 27.2 | 27.0 | 27.6 | 28.1 | 26.4 | 27.0 | 26.8 | 27.5 | 27.9 |
| | 8H | 26.9 | 27.4 | 27.3 | 27.9 | 28.3 | 26.7 | 27.2 | 27.1 | 27.7 | 28.2 |
| Variations with the observer position at spacings(CIE Pub.117): | | | | | | | | | | | |
| S = 1.0H | | + 0.1 / - 0.2 | | | | | + 0.1 / - 0.2 | | | | |
| 1.5H | | + 0.2 / - 0.3 | | | | | + 0.2 / - 0.3 | | | | |
| 2.0H | | + 0.2 / - 0.3 | | | | | + 0.2 / - 0.3 | | | | |

CIE Pub.117, 970.0 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -0.1)
Area: 0.016384 m2

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:24 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

| | | |
|-----------------------------|-------------|------------------|
| NAME: 99XLED637W | TYPE: | WEIGHT: 1 |
| SPEC.: | DIM.: F 170 | SERIAL No.: 0 |
| MFR.: Elmark Industries JSC | SUR.: round | Shielding Angle: |


| REFLECTANCE | | | | | | | | | | |
|----------------------------------|--|-----|-----------|-----|-----|-----|-----|---------------|-----|--------|
| Ceiling | 0.8 | 0.8 | 0.8 | 0.7 | 0.7 | 0.7 | 0.5 | 0.5 | 0.5 | 0 |
| Walls | 0.7 | 0.5 | 0.3 | 0.7 | 0.5 | 0.3 | 0.7 | 0.5 | 0.3 | 0 |
| Working plane | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0 |
| ROOM INDEX | UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$ | | | | | | | | | |
| $k = 0.60$ | 45 | 36 | 30 | 44 | 36 | 30 | 43 | 35 | 30 | 25 |
| 0.80 | 53 | 44 | 38 | 52 | 43 | 38 | 51 | 43 | 37 | 32 |
| 1.00 | 59 | 51 | 45 | 58 | 50 | 45 | 57 | 51 | 44 | 39 |
| 1.25 | 65 | 57 | 51 | 64 | 56 | 51 | 62 | 55 | 50 | 44 |
| 1.50 | 69 | 61 | 56 | 68 | 60 | 55 | 65 | 59 | 54 | 48 |
| 2.00 | 74 | 68 | 62 | 73 | 67 | 62 | 70 | 65 | 61 | 54 |
| 2.50 | 77 | 71 | 67 | 76 | 70 | 66 | 73 | 68 | 64 | 58 |
| 3.00 | 80 | 75 | 70 | 78 | 73 | 69 | 75 | 71 | 68 | 61 |
| 4.00 | 83 | 79 | 75 | 81 | 77 | 74 | 78 | 75 | 72 | 65 |
| 5.00 | 85 | 81 | 78 | 83 | 80 | 77 | 80 | 77 | 75 | 67 |
| ROOM INDEX | UF(total) | | | | | | | | | Direct |
| According to DIN EN 13032-2 2004 | | | Suspended | | | | | SHRNOM = 1.25 | | |

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature: 25.3°C
Operators:
Test Date: 24 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

| | | |
|-----------------------------|-------------|------------------|
| NAME: 99XLED637W | TYPE: | WEIGHT: 1 |
| SPEC.: | DIM.: F 170 | SERIAL No.: 0 |
| MFR.: Elmark Industries JSC | SUR.: round | Shielding Angle: |




C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: MEDIUM
 Temperature: 25.3°C
 Operators:
 Test Date: 24 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

AAI Figure

| | | |
|-----------------------------|-------------|------------------|
| NAME: 99XLED637W | TYPE: | WEIGHT: 1 |
| SPEC.: | DIM.: F 170 | SERIAL No.: 0 |
| MFR.: Elmark Industries JSC | SUR.: round | Shielding Angle: |




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: MEDIUM
 Temperature: 25.3°C
 Operators:
 Test Date: 24 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM

| | | |
|-----------------------------|-------------|------------------|
| NAME: 99XLED637W | TYPE: | WEIGHT: 1 |
| SPEC.: | DIM.: F 170 | SERIAL No.: 0 |
| MFR.: Elmark Industries JSC | SUR.: round | Shielding Angle: |



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature: 25.3°C
Operators:
Test Date: 24 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

LED Avg.L Report

| | | |
|-----------------------------|-------------|------------------|
| NAME: 99XLED637W | TYPE: | WEIGHT: 1 |
| SPEC.: | DIM.: F 170 | SERIAL No.: 0 |
| MFR.: Elmark Industries JSC | SUR.: round | Shielding Angle: |


| AvgL | cd/m2 |
|------------------|-------|
| L_0~180 (65) av | 13888 |
| L_0~180 (75) av | 12363 |
| L_0~180 (85) av | 9416 |
| L_90~270 (65) av | 13872 |
| L_90~270 (75) av | 12337 |
| L_90~270 (85) av | 9393 |
| L_45 (65) av | 13884 |
| L_45 (75) av | 12331 |
| L_45 (85) av | 9350 |

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:24 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: MEDIUM
 Temperature: 25.3°C
 Operators:
 Test Date: 24 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```